

P255-15605

ADDENDUM NUMBER 2

SHERMAN PARK
BOYS AND GIRLS CLUB
HVAC RENOVATION
Site #791, Bldg. #2145
3000 North Sherman Boulevard
Milwaukee, WI 53210

Project Number: P255-15605

Notice Number: 7082

Date of Addendum: March 18, 2016

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated January 20, 2016, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

BIDDING, CONTRACT DOCUMENTS AND DRAWINGS

CONTRACTOR QUESTIONS

- 1) Please confirm that in base bid we are to include all piping, isolation valves and accessories when we install new control valves on existing CUH, Fin Tube and Unit Heaters in base bid as shown on M0.4.
RESPONSE: CORRECT. DETAILS INDICATE POINT OF CONNECTION (POC).
- 2) If the above is correct please confirm then that the unit pricing for cuh, units heaters will only include the cost to remove the item and the cost to furnish and install a new item, the pvf will have been covered in base bid, please confirm.
RESPONSE: CORRECT
- 3) For all VAV boxes we furnish and install in base bid we will be including, along with the control valves all new isolation valves and accessories as shown on M0.4, please confirm.
RESPONSE: CORRECT. DETAILS INDICATE POINT OF CONNECTION (POC).
- 4) Addendum 2 will extend the job past 150 days if the shutdown starts in August and lasts 8 weeks, please advise new job duration.
RESPONSE: CHANGE DURATION FOR SUBSTANTIAL COMPLETION FROM 150 DAYS TO 210 DAYS.
- 5) Are we able to work above ceilings replacing VAV boxes during late spring and the summer, if so will the building be busy and we should plan on working second shift, please advise.
RESPONSE: FOR ANY WORK ABOVE THE CEILING FOR PERIOD OTHER THAN THE 8 WEEKS SHUT DOWN SHOULD BE SCHEDULED AFTER 4 PM (SECOND SHIFT) MONDAY THRU FRIDAY. COORDINATE THIS WORK WITH THE BOYS AND GIRLS CLUB.

BIDDING DOCUMENTS

CHANGE Duration for substantial completion from 150 days to 210 days.

P255-15605

SPECIFICATIONS

23 73 13 – REVISE section 2.1 Manufacturers to include: Daikin

DRAWINGS

NO CHANGES

End of Addendum No. 2