

O115-13415

ADDENDUM NUMBER 3

CHILDREN'S COURT CENTER
INDEPENDENT COOLING SYSTEM
Site #360, Bldg. #5000
10201 West Watertown Plank Road
Wauwatosa, WI 53226

Project Number: O115-13415

Date of Addendum: May 29, 2013

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated May 3, 2012, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

This Addendum consists of 1 page

BIDDING DOCUMENTS

1. None

GENERAL REQUIREMENTS (DIVISION 01):

2. None

SPECIFICATIONS (DIVISIONS 02 THRU 33):

3. None

DRAWINGS

4. Sheet M140, Plate and Frame Heat Exchanger Schedule:
CHANGE maximum pressure drop on the cold and warm fluid side from FT WG to PSIG.
Numbers as indicated are PSIG values.
5. Sheet M140, Air Separator Schedule:
CHANGE manufacturer from B & G CRS to B & G RL to match tangential air separator
specification requirements.

End of Addendum No. 3