

ADDENDUM NUMBER 3

MILWAUKEE COUNTY ZOOLOGICAL GARDENS
WINTER QUARTERS ROOF AND ASPHALT DRIVEWAY REPLACEMENT
Site #355, Bldg. #4670
10001 West Blue Mound Road
Milwaukee, WI 53226

Project Number: Z063-09478

Date of Addendum: June 17, 2013

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated May 29, 2013, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

SPECIFICATIONS

Section 07135:

Part 2 PRODUCTS

2.02 – A –1. –a)

Change the paragraph to read:

"80 mil (2.0mm) thermoplastic flashing membrane with fiberglass reinforcement, and be compatible with waterproof membrane."

2.02 – A –2. –a)

Change the paragraph to read:

"60 mil (1.5 mm) thermoplastic flashing membrane with fiberglass reinforcement, and be compatible with waterproof membrane."

2.02 – A –2. –b)

Change the paragraph to read:

"60 mil (1.5 mm) thermoplastic asphalt resistant grid and flashing membrane with fiberglass reinforcement, and be compatible and with waterproof membrane."

2.02 – B –1.

Change paragraph to read

1. Membrane Flashing Adhesive

Adhesive product compatible with waterproof membrane, for membrane flashings in area where self-adhered membrane is not used.

2.02 – B –2.

Delete this item.

2.02 – C –1.

Change "Sarnacted SS" to "Sheet Metal Flashing compatible with waterproof membrane".

2.02 – C –4.

Change "Zamac Nail-In Fasteners" to "Flashing Fasteners".

2.02 – C –5 through 8.

Delete these items.

Part 3 Execution

3.03-A

Delete the names "SikaQuick 1000", "Sikadur Crack Fix" and "Sikadur 35 Hi-Mod LV"

Z063-09478

3.04-B

Delete the name "Sarnafil"

3.05-A-2

Delete this item

3.06-C

Delete the name "Zamac Nail-In".

3.06-D

Change the name "Sika Sarnafil" to "waterproof membrane manufacturer"

3.06-E

Delete the name "Sarnacorners - Universal".

Section O7620:

Part 2 PRODUCTS

2.1 SHEET METAL FLASHING AND TRIM

Add item B as follow

B. Scuppers: Scuppers shall be fabricated from stainless steel sheets or other corrosion resistant sheet metal compatible with and weldable to waterproof membrane.

DRAWINGS

Sheet A10

1. Drawing 1/A10:

Add the following to the note: "EXISTING ASPHALTIC WATERPROOFING TO REMAIN IN PLACE" and the statement "COVER EXISTING MEMBRANE WITH 6 MIL POLYETHYLENE BARRIER PER SPEC."

End of Addendum No. 3