

P090-10614-5, P090-10616-3A & P171-10613-4A

ADDENDUM NUMBER: 1

MILWAUKEE COUNTY PARKS
SWIMMING POOL IMPROVEMENTS

Contract 3A - Washington Supply Channel Replacement
Project Number P090-10616-3A
1859 North 40th Street (4023 W. Galena St.)
Milwaukee, WI 53208

Contract 4A - McCarty Supply Channel Replacement
Project Number P171-10613-4A
2567 South 79th Street
West Allis, WI 53219

Contract 5 - McCarty Concrete Tunnel Top, Curb, & Deck Replacement
Project Number P090-10614-5
2567 South 79th Street
West Allis, WI 53219

Date of Addendum: August 15, 2011

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated July 29, 2011, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

Drawing Sheets C-1 and C-2, Sheet 2 and 3 of 5 – McCARTY AND WASHINGTON CONVERSION OF SUPPLY CHANNEL TO INLETS

Detail 2 – Add note: Dowels shall be tied to longitudinal rebar and bonded to existing pool grid.

Drawing Sheets C-2, Sheet 3 of 5 – McCARTY SWIMMING POOL CONVERSION OF SUPPLY CHANNEL TO INLETS

Gutter Lip Note on Upper Right Side of Sheet – Add to Note: Remove paint from gutter lip and prepare concrete surface according to manufacturer's instructions.

Drawing Sheet C-3, Sheet 4 of 5 – McCARTY SWIMMING POOL TUNNEL TOP, DECK SLAB, AND CURB REPLACEMENT

Tunnel Note on Right Side of Sheet – Delete sentence: "PROVIDE TEMPORARY SUPPORT OF PIPING AND CONDUITS ATTACHED CEILING OF TUNNEL."

Replace with: "PROTECT PIPING, CONDUITS, AND FIXTURES IN THE TUNNEL. OWNER WILL RETAIN ELECTRICIAN TO REMOVE UNDERWATER POOL LIGHTING CONDUITS AND JUNCTION BOXES, RELOCATE CONDUITS LESS THAN ONE-INCH DIAMETER AND TUNNEL LIGHT FIXTURES ATTACHED TO THE CEILING, AND SUPPORT CONDUITS AND OTHER ITEMS TO REMAIN FROM THE TUNNEL WALLS."

Add sentence: "ALL EXTERIOR ITEMS ATTACHED TO OR THROUGH TUNNEL TOP, INCLUDING DIVING STANDS, GUARD STANDS, LADDERS, FENCE POSTS, AND BASKETBALL HOOP SLEEVES, SHALL BE RE-INSTALLED."

Note for Wall on North Side of Wading Pool – Add sentence: "Replace five large diameter fence posts with new posts to match existing."

End of Addendum No. 1

00900-1