

ADDENDUM NO. 3

GMIA SECURITY & WILDLIFE DETERRENT PERIMETER FENCING - 2013

GMIA Project No. A125-13009

GENERAL MITCHELL INTERNATIONAL AIRPORT
5300 SOUTH HOWELL AVENUE
MILWAUKEE WISCONSIN 53207

OFFICIAL NOTICE NO. 6839

GENERAL MITCHELL INTERNATIONAL AIRPORT
Milwaukee County, Wisconsin

Prepared By: MILWAUKEE COUNTY DEPARTMENT OF ADMINISTRATION
ARCHITECTURE, ENGINEERING, AND ENVIRONMENTAL SERVICES
AIRPORT ENGINEERING UNIT
5300 SOUTH HOWELL AVENUE
MILWAUKEE, WI 53207
Telephone 414-747-5774

DATE OF ADDENDUM: July 15, 2013

BIDS CLOSE: 2:00 P.M., Wednesday, July 17, 2013.

NOTE BID LOCATION CHANGE IN ADDENDUM

TO ALL BIDDERS:

Each bidder shall read this Addendum in its entirety to determine to what extent his proposal and the contract conditions will be affected. This Addendum to the Contract Documents is issued to modify, explain, or correct the original documents and is hereby made part of the Contract Documents.

RECEIPT – Sign the following receipt and attach to submitted Proposal Form.

Receipt of Addendum No. 3, consisting of two (2) pages, for the GMIA Security & Wildlife Deterrent Perimeter Fencing - 2013, Official Notice No. 6839, at General Mitchell International Airport, Milwaukee, Wisconsin, dated July 15, 2013, is acknowledged.

Date _____

Firm _____

Per _____

Address _____

PART 1 – BIDDER CLARIFICATIONS

- 1.1 Bidders' request clarification on whether the fill to be removed in fenceline 11 is contaminated.
 - A. *Response: Bids should assume the fill is not environmentally contaminated and that the fill is to be removed and disposed of offsite.*
- 1.2 Bidders' request clarification on extent of electrical work to be done on the gate operators of gate 4A.
 - A. *Response: Bids should include all electrical work associated with the gate operator installation. Electricity is currently located onsite at the location of the existing gate operators. No new electrical runs will be required from the current operators to the building. GMIA electricians will assist in providing access to turn on/off electricity to the operators from the building, but disconnection and reconnection of the operators are to be included in the bid.*

PART 2 – REVISIONS TO THE PROJECT MANUAL

- 1.1 Page 1.1: OFFICIAL NOTICE OF RECEPTION OF BIDS, 3rd Section: BIDS shall be removed and replaced with:
Sealed bids are due at 2711 W. Wells St; Milwaukee, WI 53208, Plan Desk Room 201 no later than 2 PM, Wednesday, July 17, 2013.

Bids will be publically read 5 minutes after Bid due time at 2711 W Wells St; Milwaukee, WI 53208, Plan Desk Room 201.

PART 3 – REVISIONS TO THE DRAWINGS

- 1.1 Remove and replace Note 3 of "Fence Construction Sequencing Guidelines" of sheet 7 to read:
 3. FENCE SEGMENT 20 AND ASSOCIATED GATES MAY BE REMOVED AND REPLACED DAILY IN MAXIMUM LENGTHS OF 300'. DURING THIS TIME CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING TEMPORARY PERMIETER AIRFIELD SECURITY RESTRICTING ALL ACCESS TO THE SECURED AREAS. THERE SHALL BE NO GAPES PER PROJECT GENERAL NOTES. IN LIUE OF DAILY REMOVAL AND REPLACEMENT, A TEMPORARY FENCE MAY BE INSTALLED TO THE EAST OF THE ORIGINAL FENCE. THIS TEMPORARY FENCE SHALL BE CONSTRUCTED ACCORDING TO DETAIL 7 ON SHEET 11, EXCEPT THE POSTS MAY BE EMBED 5'-0" INTO SOIL IN LIUE OF THAT SHOWN ON THE DETAIL. FULL CLOSURE TO BUIDLING AND ORIGINAL SIDA FENCELINE IS REQUIRED FOR TEMPORARY FENCE.