

ADDENDUM NO. 1

GMIA SECURITY & WILDLIFE DETERRENT PERIMETER FENCING - 2013

GMIA Project No. A125-13009

GENERAL MITCHELL INTERNATIONAL AIRPORT
5300 SOUTH HOWELL AVENUE
MILWAUKEE WISCONSIN 53207

OFFICIAL NOTICE NO. 6839

GENERAL MITCHELL INTERNATIONAL AIRPORT
Milwaukee County, Wisconsin

Prepared By: MILWAUKEE COUNTY DEPARTMENT OF ADMINISTRATION
ARCHITECTURE, ENGINEERING, AND ENVIRONMENTAL SERVICES
AIRPORT ENGINEERING UNIT
5300 SOUTH HOWELL AVENUE
MILWAUKEE, WI 53207
Telephone 414-747-5774

DATE OF ADDENDUM: July 3, 2013

BIDS CLOSE: 2:00 P.M., Wednesday, July 7, 2013

TO ALL BIDDERS:

Each bidder shall read this Addendum in its entirety to determine to what extent his proposal and the contract conditions will be affected. This Addendum to the Contract Documents is issued to modify, explain, or correct the original documents and is hereby made part of the Contract Documents.

RECEIPT – Sign the following receipt and attach to submitted Proposal Form.

Receipt of Addendum No. 1, consisting of two (2) pages, for the GMIA Security & Wildlife Deterrent Perimeter Fencing - 2013, Official Notice No. 6839, at General Mitchell International Airport, Milwaukee, Wisconsin, dated July 3, 2013, is acknowledged.

Date _____

Firm _____

Per _____

Address _____

PART 1 – BIDDER'S CLARIFICATIONS

1.1 Bidders' request a clarification as to extent of consolidation required at trench backfill.

- A. *Response: Refer to specification project manual ITEM 02324, Section 3.6 (pages 26.8- 26.9) for compaction requirements.*

PART 2 – REVISIONS TO THE PROJECT MANUAL

2.1 ITEM F-162, Section 2.3 shall be deleted in its entirety and replaced with the following:

Posts, rails, and braces shall conform to the requirements of ASTM F-1043 or ASTM F-1083 as follows.

Galvanized tubular steel pipe shall conform to the requirements of Group IA, (Schedule 40) coatings conforming to Type A, or Group IC (High Strength Pipe), External coating Type B, and internal coating Type B or D.

Roll Formed Steel Shapes (C-Sections) shall conform to the requirements of Group IIA, and be galvanized in accordance with the requirements of F 1043, Type A.

Hot-Rolled Shapes (H Beams) shall meet the requirements of Group III, and be galvanized in accordance with the requirements of F 1043, Type A.

Aluminum Pipe shall conform to the requirements of Group IB.

Aluminum Shapes shall conform to the requirements of Group IIB.

Posts, rails, and braces, with the exception of galvanized steel conforming to F 1043 or ASTM F 1083, Group 1A, Type A, or aluminum alloy, shall demonstrate the ability to withstand testing in salt spray in accordance with ASTM B 117 as follows:

External: 1,000 hours with a maximum of 5% red rust.

Internal: 650 hours with a maximum of 5% red rust.

The dimensions of the posts, rails, and braces shall be in accordance with Tables I through VI of Fed. Spec. RR-F-191/3.

PART 3 – REVISIONS TO THE DRAWINGS

3.1 On sheet 6 of 12, Fence segment 15 shall be moved 100' to the West. This results in no changes to quantities.