

T056-13426

**ADDENDUM NUMBER 2**

MILWAUKEE COUNTY TRANSIT SYSTEM  
KINNICKINNIC TRANSPORTATION BUILDING  
HVAC SYSTEM REPLACEMENT  
Site #200, Bldg. #80  
1710 South Kinnickinnic Avenue  
Milwaukee, WI 53204

Project Number: T056-13426

Date of Addendum: August 1, 2013

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated July 3, 2013, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

**BIDDING DOCUMENTS**

**SPECIFICATIONS**

1. Specification Section 23 09 00, 23 72 23, **DELETE:** all references to BACNet compatibility, interfaces, and options from specifications: **ADD:** "Air Handling Unit AHU-1, Energy Recovery Unit ERU-1, and Condensing Unit ACCU-1 shall be provided with terminal strips by the manufacturer for connection to and control by the Invensys Controls DDC Controls system."

**DRAWINGS**

1. Sheet M0.0: Energy Recovery Unit Schedule: **DELETE:** reference to "BACNet interface and control" under Notes:. **ADD:** "ERU-1 shall be provided with terminal strip for connection to and control by the Invensys Controls DDC Controls System."
2. Sheet M0.0: Air Cooled Condensers Schedule: **DELETE:** reference to "BACNet communications option" under Notes:. **ADD:** "ERU-1 shall be provided with terminal strip for connection to and control by the Invensys Controls DDC Controls System."
3. Sheet M2.0, Mechanical Construction Plan: **ADD:** Airflow Measuring Station in 26/18 Outside Air Duct to ERU-1. **ADD:** Air Flow Measuring Stations to supply and return fans of AHU-1.

**End of Addendum No. 2**

00900-1