

5041-10006

ADDENDUM NUMBER 1

GENERAL MITCHELL INTERNATIONAL AIRPORT
TRAVELERS INFORMATION STATION
RE-BID
Site #290, Bldg. #190
5300 South Howell Avenue
Milwaukee, WI 53207

Project Number: 5041-10006

Date of Addendum: September 19, 2011

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated August 26, 2011, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

BIDDING AND CONTRACT DOCUMENTS

Section 01100- Summary

ADD the following to Article 1.3: All "core drilling" through floors shall be X-Ray'd to determine floor conditions prior to drilling.

ADD the following to Article 1.4: General Terminal Working Hours permitted are from 10 PM to 4 AM, however, daytime hours will be granted on a case by case method.

Section 01500- Temporary Facilities and Controls

ADD the following to Article 1.13:

All structure and surface parking regulations shall be followed. Any drop off of materials shall be determined and approved by GMIA Security on a case by case request.

General: Pre-bid meeting information attendance list is attached with this Addendum 1.

DRAWINGS

Sheet A100 – Floor Plan and Reflected Ceiling Plan

REVISE Electrical Layout General Notes: The new panel shall have a 40amp main 3 phase 120/208v with space for 12 single pole breakers to be mounted on the column in front of the doors to provide 3 feet of clearance. The panel shall be labeled NLT2A. The new panel shall be fed from panel 14/AP located in room T155 locking on the first floor of the ticketing area, approximately 20 feet south of the column. Panel 14/AP is a GE AQF3302MBX. Provide a 40amp 3 pole breaker in available space.

Sheet A100 – Floor Plan and Reflected Ceiling Plan

REVISE Lighting Layout Keyed Notes: The bendable track head shall be Bruck LEDRA chroma spot 137310mc/fl, LED with 60 degree reflector. Provide compatible mounting components.

End of Addendum No. 1

00900-1

MILWAUKEE COUNTY
Dept. of Transportation and Public Works
PRE-BID MEETING for Re-Bid of the
Travelers Information Station
at GMIA

Project Number: 5041-10006

DATE: 9-14-11

PLACE: GMIA, Hardie Room

NAME	ORGANIZATION	PHONE	EMAIL
Bernie Mielcarek	DT & PW - B & E Div	414.238.3987	Bernard.Mielcarek@milwcnty.com
Andy Seiter	Hunzinger Construction	262-797-0797	aseiter@hunzinger.com
Rich Grasso	TRIAD CONST.	414-350-0516	Rg@TRIADGC.COM
WILFREDO RIVERA	GMIA - IT	414-747-3725	wrivera@mitchellairport.com
George Knops	GMIA - IT	414-747-6236	gknops@mitchellairport.com
James Phelps	JCP Construction	414-372-7300	James@jcp-construction.com
SHAWN GIFFIN	KPH CONSTRUCTION	414-647-1530	Sgiffin@kphbuilds.com
Bruce Nelson	Nelco Electric	262-874-5201	Bruce.N@NelcoElectric
Jon Olson	VENTURE Electric	414-588-9263	JonO@VENTURE-electric.com
Ryan McAdams	GMIA - PR	414-747-5316	rmcadas@mitchellairport.com
Mary Turner	GMIA Engineers	747-6233	MTURNER@mitchellairport.com
Joe Podewils	Dnesco Electric	425-3700	jpodewils@dnesco.com
Mike Kagan	GMIA - SECURITY	747-4535	MKEKAGAN@mitchellairport.com

(RO - 7/98)