

O060-10617

ADDENDUM NUMBER 1

MILWAUKEE COUNTY SPORTS COMPLEX  
PARKING LOT RECONSTRUCTION  
Site #628, Bldg. #5800  
6000 West Ryan Road  
Franklin, WI

Project Number: O060-10617

Date of Addendum: November 8, 2011

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated October 14, 2011, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

SECTION 02785 – INTERLOCKING CONCRETE PAVERS  
Add Part 2 Products, Section 2.01, Part A Item 3:

PaveDrain System Blocks  
As manufactured by:  
ECS Solutions, LLC  
PMB 292  
7245 S. 76<sup>th</sup> Street  
Franklin, WI 53132  
Contact: Doug Buch Cell 414-630-1012, Office 414-423-6531

Note:

The PaveDrain paver brick is thicker than the specified Unilock paver or the Paveloc paver. The finish grade elevation at the top of the pavers shall remain the same. The stone layer thickness below the pavers shall remain the same. Lower the subgrade elevations and underdrain invert elevations to accommodate the additional thickness in the pavers. All other modifications necessary to accommodate changes in paver thickness are the responsibility of the contractor.

End of Addendum No. 1