

ADDENDUM NUMBER 2

CRIMINAL JUSTICE FACILITY
 COOLING TOWER REPLACEMENT
 Site #240, Bldg. #76
 949 North 9th Street
 Milwaukee, WI 53233

Project Number: C103-13645

Notice Number: 6955

Date of Addendum: September 5, 2014

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated August 11, 2014, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

SPECIFICATIONS

SECTION 23 05 23 GENERAL DUTY VALVES FOR HVAC

INSERT THE FOLLOWING:

2.01. MANUFACTURERS.

Insert to the list Keystone, or Equal

SECTION 23 07 00 HVAC INSULATION

INSERT THE FOLLOWING:

3.03. PIPING, VALVES AND FITTING INSULATION

| <u>Service Types</u> | <u>Insulation</u> | <u>Jacket</u> | <u>Insulation Thickness By Pipe Size</u> | | | | |
|---------------------------------------------|---------------------|---------------|-------------------------------------------------|---------------|---------------------------|---------------------------|-------------------------------|
| | | | <u>1-1/4"</u> <u>&</u> <u>smaller</u> | <u>1-1/2"</u> | <u>2" to</u> <u>4"</u> | <u>4" to</u> <u>6"</u> | <u>8" to</u> <u>Larger</u> |
| Exterior Cooling Tower Supply and Return | Rigid Fiberglass | PMJ | 2.5" | 2.5" | 3" | 3" | 3" |

- A. PROTECTIVE METAL JACKET (PMJ)
 - 1. .016 inch thick aluminum or .010 inch thick stainless steel with safety edge.
 - 2. Provide a protective metal jacket (PMJ) with lap seams a minimum of 2 inches. Secure with metal bands for end to end joints, and rivets or sheet metal screws for longitudinal joints. Rivets, screws, and bands to be constructed of the same material as the jacket. Locate seams on bottom for exterior applications.

End of Addendum No. 2