

ADDENDUM NUMBER: Addendum - Three
PROJECT TITLE: Criminal Justice Facility
PROTECTIVE GLASS BARRIER
Site Number: 240
Building Number: 76
949 North 9th Street
Milwaukee, Wisconsin 53233
PROJECT NUMBER: O433-13447
DATE OF ADDENDUM: December 03, 2014

This Addendum to the Contract Documents is issued to modify, explain or correct the original Documents, Dated NOVEMBER 03, 2014 and is hereby made part of the Contract Documents. Acknowledge receipt of this addendum in the space provided on the Bid Form, or bid maybe rejected.

SPECIFICATIONS

08 71 00 DOOR HARDWARE

Add SECTION 3.6 SCHEDULE to the door hardware specification as follows:

- A. The following hardware sets are intended to establish type and standard of quality when used together with this section requirements. Examine Drawings and Specifications and furnish proper hardware for door openings.

B. HARDWARE GROUP-1

Hinges	McKinney	Continuous geared hinge. Series: K-MCK-12HD - (supports a minimum door weight of 540 lbs.). - Finish: clear anodized aluminum (CL).
Closer	LCN	4510 Series - Finish: satin stainless steel (32D).
Locksets	Sargent	9200 Mortise Lock - Single cylinder with deadbolt. - Function: 25 dormitory or exit (ANSI F13). - J lever design - 13SKB thumb turn. - LS Escutcheon. - Finish: satin stainless steel (32D).
Electric Strike	Von Duprin	Model: 6216 - Finish: satin stainless steel (32D).