

P284-13643

ADDENDUM NUMBER 1

CLARKE SQUARE  
PLAYGROUND REPLACEMENT  
Site #761  
2330 West Vieau Place  
Milwaukee, WI

Project Number: P284-13643

Date of Addendum: September 24, 2013

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated August 23, 2013, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

BIDDING DOCUMENTS

SCHEDULE OF PRICES- (00410-3.1 thru 00410-3.2)

ADD the following for Item No. 1: All existing sand shall be removed.

CHANGE the following for Item No. 10: Estimated Quantity to 280 Ton. Provide and install minimum 6-inch compacted depth, or as required to make up the difference of removing all sand, of 3/4-inch, crushed limestone TB base course over entire 4,130 sq. ft. playground interior subgrade. Recompact base after equipment installation.

End of Addendum No. 1