

G017-14425, G018-14426, G019-14427

ADDENDUM NUMBER 2

MILWAUKEE COUNTY  
FIRE ALARM SYSTEM REPLACEMENTS  
at

Vel Phillips Children's Court Center  
10201 West Watertown Plank Road  
Wauwatosa, WI 53226  
Project Number: G017-14425

Research Park Technology Center  
10437 Innovation Drive  
Wauwatosa, WI 53226  
Project Number: G018-14426

Child & Adolescent Treatment Center  
9501 Watertown Plank Road  
Wauwatosa, WI 53226  
Project Number: G019-14427

Notice Number: 7017

Date of Addendum: June 8, 2015

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated April 15, 2015, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

BIDDING AND CONTRACT CONDITIONS

CHANGES TO SPECIFICATIONS:

1. None

CHANGES TO DRAWINGS:

**VEL PHILLIPS CHILDREN'S COURT CENTER  
10201 WEST WATERTOWN PLANK ROAD  
PROJECT NUMBER: G017-14425**

2. Sheet E901, **CLARIFICATION** the Fire Alarm Riser Diagram is a general schematic of the interconnection of the fire alarm systems components and devices, it is not intended to represent an installation wiring diagram, nor to show the specific qualities of devices, annunciators or components required. The contractor shall provide devices and annunciator panels as indicated on the building floor plans.

**RESEARCH PARK TECHNOLOGY CENTER  
10437 INNOVATION DRIVE  
PROJECT NUMBER: G018-14426**

3. Sheet E901, **CLARIFICATION** the Fire Alarm Riser Diagram is a general schematic of the interconnection of the fire alarm systems components and devices, it is not intended to represent an installation wiring diagram, nor to show the specific qualities of devices, annunciators or components required. The contractor shall provide devices and annunciator panels as indicated on the building floor plans.

**CHILD & ADOLESCENT TREATMENT CENTER  
9501 WEST WATERTOWN PLANK ROAD  
PROJECT NUMBER: G019-14427**

4. Sheet E901, **CLARIFICATION** the Fire Alarm Riser Diagram is a general schematic of the interconnection of the fire alarm systems components and devices, it is not intended to represent an installation wiring diagram, nor to show the specific qualities of devices, annunciators or components required. The contractor shall provide devices and annunciator panels as indicated on the building floor plans.
5. Sheet E901, **CLARIFICATION** the Fire Alarm Riser Diagram is not intended to require networked fire alarm control panels with buildings of the Child & Adolescent Treatment Center. Each fire alarm control panel is an independent system with connection to the existing auto dialers for reporting to Milwaukee County' monitoring company.

End of Addendum No. 2