

HAMMEL, GREEN AND ABRAHAMSON, INC.
ARCHITECTS AND ENGINEERS
HGA Commission Number: 1215-009-00

Date: April 20, 2015

Page 1 of 2

PROJECT: GMIA EDB Data Center
5300 S. Howell Avenue
Milwaukee, Wisconsin 53207

COPY: Mary Turner – GMIA
Paul Gruetner – HGA
Gary Merkl – HGA

PRIME CONSULTANT – MEP/IT ENGINEER:
HAMMEL GREEN AND ABRAHAMSON, INC
333 East Erie Street
Milwaukee, Wisconsin 53202-6005

ARCHITECT: STANDING STONE DESIGN, INC.
15150 West Kingsway Drive
New Berlin, Wisconsin 53151

CONSTRUCTION MANAGER: MILWAUKEE COUNTY
General Mitchell International Airport
5300 S. Howell Avenue
Milwaukee, Wisconsin 53207

Pursuant to the Integrated Agreement for Project Delivery, the following supplemental instructions are to be included in the work. Please acknowledge your acceptance of these supplemental instructions and return a signed copy with any comments noted to the Architect.

DESCRIPTION OF THE WORK:

1. Scale on Architectural plan A102 Detail 2/A102 CHANGE from 1/4" = 1'-0" to 1/8" = 1'-0"
2. Mechanical sheet M200 clarification and updated CCD-1 information

Part I. SPECIFICATIONS

- a. NA

Part II. DRAWINGS

1. Sheet M200
 - a. Clarification to clean agent fire suppression note.
 - b. Updated information to CCD-1

END OF DOCUMENT

ATTACHMENTS:

Sheet M200

Issued By: _____
HAMEL GREEN AND ABRAHAMSON, INC.
Paul Gruetner, P.E.

Accepted By: _____
Contractor: _____


COMMENTS:

COMPUTER ROOM AIR CONDITIONING UNIT (AC)													
FLOOR	LOCATION	QTA	QTY	HP	HP/W	TON	CONDENSER DATA			EVAPORATOR DATA			NOTES
							CONDENSER	MODEL	MANUFACTURE	CONDENSER	MODEL	MANUFACTURE	
AC1	FLOOR 002	14,000	3	18	6.5	283	283	283	283	283	283	283	11.2.1
AC2	FLOOR 002	14,000	3	18	6.5	283	283	283	283	283	283	283	11.2.1

NOTES:

- SEE ELECTRICAL NOTION SCHEDULES FOR WIRING AND PHASING INFORMATION.
- PROVIDE VENTILATION FOR AIR FROM ROOM THROUGH EXHAUST ROOF CURB AND RETURN REEF.
- PROVIDE VENTILATION FOR AIR FROM ROOM THROUGH EXHAUST ROOF CURB AND RETURN REEF.
- CONDENSER COILS IN THIS CABINET SHALL BE CLEANED AND MAINTAINED PER MANUFACTURER'S RECOMMENDATIONS.
- AC1 IS TO BE AS AN ALTERNATE LOCATION. CONDENSER COILS AND ALL ASSOCIATED EQUIPMENT TO REMAIN IN PLACE PER EXISTING CONTRACT FOR THE INSTALLATION OF AC1.

DIFFUSERS, REGISTERS, AND GRILLES SCHEDULE									
TYPE	SIZE	MATERIAL	FINISH	REMARKS					
DIFFUSER	18" X 18"	ALUMINUM	POWDER COAT	FOR USE IN OFFICE					
REGISTER	18" X 18"	ALUMINUM	POWDER COAT	FOR USE IN OFFICE					
GRILLE	18" X 18"	ALUMINUM	POWDER COAT	FOR USE IN OFFICE					



GENERAL PLUMBING NOTES

- THE CONTRACTOR IS RESPONSIBLE FOR ALL CITY AND STATE PERMITS AND FEES FOR ALL PLUMBING WORK. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FEES. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FEES.
- ALL PLUMBING WORK SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST EDITIONS OF THE PLUMBING CODES AND STANDARDS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FEES.
- ALL PLUMBING WORK SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST EDITIONS OF THE PLUMBING CODES AND STANDARDS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FEES.
- ALL PLUMBING WORK SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST EDITIONS OF THE PLUMBING CODES AND STANDARDS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FEES.
- ALL PLUMBING WORK SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST EDITIONS OF THE PLUMBING CODES AND STANDARDS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FEES.
- ALL PLUMBING WORK SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST EDITIONS OF THE PLUMBING CODES AND STANDARDS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FEES.
- ALL PLUMBING WORK SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST EDITIONS OF THE PLUMBING CODES AND STANDARDS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FEES.
- ALL PLUMBING WORK SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST EDITIONS OF THE PLUMBING CODES AND STANDARDS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FEES.
- ALL PLUMBING WORK SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST EDITIONS OF THE PLUMBING CODES AND STANDARDS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FEES.
- ALL PLUMBING WORK SHALL BE INSTALLED IN ACCORDANCE WITH THE LATEST EDITIONS OF THE PLUMBING CODES AND STANDARDS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FEES.

<p>STANDING STONE DESIGN, Inc. 18601 W. Bluemound Road, Suite 220 Brookfield, Wisconsin 53005 Phone: (262) 706-1900</p>		<p>MILWAUKEE COUNTY DEPARTMENT OF ADMINISTRATIVE SERVICES 831 W. WISCONSIN AVENUE, MILWAUKEE, WI 53201</p>	
<p>SHEET NO: M200</p> <p>PROJECT NO: GMA # 5041-15009 HGA #: 1215-009-01 SSD #: 11-001</p>	<p>SITE NO: 290</p> <p>BUILDING NO: 1-08A</p>	<p>PROJECT TITLE: GMA - EDB DATA CENTER 5300 SOUTH HOWELL AVENUE, MILWAUKEE, WISCONSIN 53207</p> <p>SHEET DESCRIPTION: ELECTRICAL DISTRIBUTION BUILDING - HVAC PLAN</p>	<p>SCALE: 1/8" = 1'-0"</p> <p>DATE: MARCH 30, 2015</p> <p>DRAWN BY: M KRUEGER CHECKED BY: K POPE</p>