

5051-13458

ADDENDUM NUMBER 1

GENERAL MITCHELL INTERNATIONAL AIRPORT
MAINTENANCE AND SERVICE OF EMERGENCY GENERATORS
5300 SOUTH HOWELL AVENUE
MILWAUKEE, WI 53207

Project Number: 5051-13458
Notice Number: 6878

Date of Addendum: November 11, 2013

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated October 21, 2013, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

BIDDING DOCUMENTS

CHANGE Bid Due Date to November 20, 2013 at 2:00 P.M.

PRE-BID MEETING PROJECT CLARIFICATIONS

1. Battery replacements are not part of Service Agreement Contract. If needed, they are billed as additional Work
2. Some but not all generator units have a set of connection lugs in place to connect the load bank cables (an exact list is not available at this time). Bidder shall plan to disconnect and reconnect cabling for the annual load bank test.
3. Baggage building ramp to the basement level on the south end of the baggage building will remain after the construction renovation. The ramp will be rebuilt as part of the renovation project.

End of Addendum No. 1