

ADDENDUM NO. 4

GMIA, PARKING STRUCTURE RELIGHTING-PHASE 2

PROJECT NO. A096-10012

GENERAL MITCHELL INTERNATIONAL AIRPORT  
Milwaukee County, Wisconsin

Prepared By: MILWAUKEE COUNTY DEPARTMENT OF ADMINISTRATIVE SERVICES  
ARCHITECTURE AND ENGINEERING UNIT  
Airport Engineers - Telephone 414-747-5320  
5300 South Howell Avenue  
Milwaukee, Wisconsin 53207

DATE OF ADDENDUM: October 26, 2015

BIDS DUE: 2:00 P.M., October 28, 2015

-----

TO ALL BIDDERS:

Each bidder shall read this Addendum in its entirety to determine to what extent his proposal and the contract conditions will be affected. This Addendum to the Contract Documents is issued to modify, explain, or correct the original documents and is hereby made part of the Contract Documents.

-----

RECEIPT - Sign the following receipt and attach to submitted Proposal Form.

-----

Receipt of Amendment No. 4, consisting of two (2) pages, for **GMIA, Parking Structure Relighting Project Phase 2** at General Mitchell International Airport, Milwaukee, Wisconsin, dated **August 30, 2015** is acknowledged.

Date \_\_\_\_\_

Firm \_\_\_\_\_

Per \_\_\_\_\_

Address \_\_\_\_\_

## CHANGES

### Drawing Clarifications

#### **Sheets PS-E1.13, PS-E1.23, E1.33, E1.43, E1.53, E1.81, E1.83 and E1.85**

**ADD:** General note to sheet – “Expansion joints in each section (Original, West and North) have 3 inch gaps, the gap between the original and west structures is at 5 inches. Contractor to install expansion fittings at all structural expansion joints.

Also install expansion fittings in straight runs of rigid nonmetallic conduit between securely mounted items to compensate for thermal expansion and contraction where the length change is anticipated to be .25 in or greater in accordance with NEC Table 352.44. Securely mounted items include boxes, cabinets, elbows, fixtures, or other conduit terminations