

A177-13004

ADDENDUM NUMBER 1:

GMA Parking Structure Stairwell Repairs
Site #290, Bldg. #400
5300 South Howell Avenue
Milwaukee, Wisconsin 53207

Project Number: A177-13004
Notice Number: 7043

Date of Addendum: September 15, 2015

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated July 28, 2015, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

BIDDING DOCUMENTS

CHANGE Bid Due Date to September 23, 2015 at 2:00 P.M.

MODIFICATIONS & CLARIFICATIONS TO TECHNICAL SPECIFICATIONS

1. Section 05 51 13 – Metal Pan Stairs:

a. Section 3.1, **ADD** paragraph B and subparagraph 1.

B. Determination of steel to be replaced.

1. Upon cleaning of the steel members, Contractor will request project engineer to inspect any questionable steel members. If member is determined to have lost 20% or more of the steel in section, it is expected that the member will be removed and replaced. If the deterioration is determined to be less significant, but structurally detrimental, the engineer may determine that a structural plate or piece may need to be welded to the member for added strength.

MODIFICATIONS & CLARIFICATIONS TO DRAWINGS

1. Sheet A-101 through A112 – plan sheets:

a. **CLARIFICATION:** Note #15, painting only includes walls. The area of walls to be painted should be only in areas that are already painted. Assume 1,000 s.f. of two coats in each stairwell for Stairs 1,2,5,7,12,13, and 15. Assume 250 s.f. of two coats in each stairwell for Stairs 3,4,6,8 and 10 for the bid as an average.

End of Addendum No. 1