

ADDENDUM NUMBER 3

JOHNSONS PARK PAVILION
Site # 771, Bldg. # 1670
1919 W Fond Du Lac Ave
Milwaukee, WI 53205

Project Number: P271-13621

Date of Addendum: July 13, 2015

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated June 24, 2015, and is hereby made part of the Contract Documents.

MODIFICATIONS & CLARIFICATIONS TO SPECIFICATIONS

1. Specification Section 01230 – Alternatives:

a. **ADD** 01230, 1,1, C, 1, as follows:

“Contract Time for work in Alternative A shall be extended by owner based on actual date of delivery of the Pre-Fabricated Site Shelter.”

2. Specification Section 07 61 00 – Sheet Metal Roofing:

a. **REVISE** 07 61 00, 2.1, D, 1, as follows:

“Two-Coat Fluoropolymer: AAMA 621, fluoropolymer finish containing not less than 70 percent PVDF resin by weight. Prepare, pre-treat, and apply coating to exposed metal surface to comply with coating and resin manufacturer’s written instructions”.

SUBSTITUTION REQUESTS

Subject to compliance with the requirements in the specifications and shop drawing or submittal review, the following substitutions have received pre-approval for bidding purposes:

1. Specification 09 67 00 - Fluid Applied Flooring

- a. 09 2667 70, 2.1 Fluid-Applied Flooring, A. Manufacturers: *Anchor Bond 4000 Decorative Quartz Flooring System* ”

End of Addendum No. 3

Substitution Request Form during Procurement

Project: Johnsons Park Pavilion
To: Milwaukee County | DAS - FM - AE&ES Section
633 W. Wisconsin Ave., Suite 1000
Milwaukee, WI 53203

Project No.: P271-13621
Substitution Request No.: _____
From: RICK FORTMANN
Date: 7-8-2015
Contract For: _____

Specification Section: _____
FLUID-APPLIED FLOORING
Section No.: 096700 Page: 2

Description: _____
Article/Paragraph: PART 2 - 2.1

Proposed Substitution: ANCHORBOND 4000 DECORATIVE QUARTZ FLOORING
Manufacturer: INDUSTRIAL PROTECTIVE COATINGS Address: 1855 ENTERPRISE DR.
Phone: 920-336-0801 Fax: 920-336-6463 ^{FAX.} DE PERE WI. 54115
Trade Name: ANCHORBOND Model No.: N/A
Installer: UNKNOWN AT THIS TIME Address: _____
Phone: _____ Fax: _____

Differences between proposed and specified product: NO SIGNIFICANT DIFFERENCES
VALUE ADDED ALTERNATE

History: New 2 - 5 years old 5 - 10 years old Greater than 10 years old
 Point-by-point comparison attached - Required

Reason for not providing specified item: PRE-BID

Similar Installation:
Project: SEE ATTACHED Design Professional: _____
Address: _____ Owner: _____
Date Installed: _____

Proposed Substitution affects which other portions of the Work: No Yes - Explain: _____

Supporting Data: Drawings Product Data Samples Tests Reports Other _____

Substitution Request Form during Procurement

The Undersigned Certifies:

- Proposed substitution has been fully investigated and determined to be equal or superior in all aspects the specified product.
- Same Warranty will be furnished for proposed substitution as for specified product.
- Same maintenance service and source of replacement parts, as applicable, is available.
- Proposed substitution will have no adverse effect on other trades and will not affect or delay progress schedule.
- Proposed substitution does to affect dimensions and functional clearances.

Submitted by:

RICK FORTMAN

Signed By:

[Signature]

Firm:

INDUSTRIAL PROTECTIVE COATINGS, INC.

Address:

1855 ENTERPRISE DR. DE PERE WI. 54115

Telephone:

920-336-0801

Fax/Email:

920-336-6463 R.FORTMAN@ANCHORBOUNDS.COM

Attachments:

FAF SPEC; AB4000 PER. QUARTZ SYSTEM; AB S/B LIQUIDS;
AB HIGH SILIOS T.C.; CHEMICAL RESISTANCE GUIDE; REF. LIST

ARCHITECT'S OR OWNER'S REVIEW AND ACTION

- Substitution approved. Make submittals in accordance with Specification Section 01330.
- Substitution approved as noted. Make submittals in accordance with Specification Section 01330.
- Substitution rejected. Use specified materials.
- Substitution Request received too late. Use specified materials.

Signed By:

Chris Traverthy, AA

Date:

07/10/14