

P208-15664

ADDENDUM NUMBER 1

MILWAUKEE COUNTY
KOSCIUSZKO PARK COMMUNITY CENTER
FIRE ALARM RENOVATION
Site #774, Bldg. #4070
2201 South 7th Street
Milwaukee, WI 53215

Project Number: P208-15664

Notice Number: 7127

Date of Addendum: September 6, 2016

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated July 29, 2016, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

BIDDING AND CONTRACT DOCUMENTS

- SilentKnight by Honeywell is an acceptable manufacturer.
- All conductors #18 AWG and larger shall be stranded, solid wire is not acceptable.
- Where existing devices are being removed, cover plates shall be used on block cement surfaces. Dry-walled surfaces shall be patched and painted to match existing.
- Existing conduit that is accessible shall be removed.
- Wiremold shall be used for vertical surfaces below the ceiling throughout the Ground Level and First Floor in lieu of red conduit.
- Wiremold shall transition to conduit for horizontal runs in all open ceiling areas.
- Wire shall be run through and sleeved through walls where at all possible.
- Areas where existing conduit is removed shall be patched and painted to match existing.
- Three (3) sets of door-hold releases shall interface with the new system.
- Existing conduit shall be extended down from existing pull station locations in the gymnasium only.
- Five (5) guards shall be provided for the horn/strobe devices in the gymnasium. Guards shall be basket-style with chrome-plated steel finish.
- Existing horns and strobes shall be salvaged in whole at the discretion of Milwaukee County.
- Use of EMT conduit is acceptable from the main panel to the ceiling cavity above.

- EMT conduit shall be used in the basement. Wiremold shall not be used.
- An extra 25 feet of wire shall be provided at each of (3) air handling unit duct detectors.
- Location of NAC panels shall be coordinated with Owner.

End of Addendum No. 1