

ADDENDUM NO. 1

**LJT – Security & Wildlife Deterrent Perimeter Fencing 2015**  
GMIA Project No. A190-15004

LAWRENCE J. TIMMERMAN AIRPORT  
9305 W APPLETON AVENUE  
MILWAUKEE WISCONSIN 53225

**OFFICIAL NOTICE NO. 7019**

LAWRENCE J. TIMMERMAN AIRPORT  
Milwaukee County, Wisconsin

**Prepared By:** MILWAUKEE COUNTY DEPARTMENT OF ADMINISTRATION  
ARCHITECTURE, ENGINEERING, AND ENVIRONMENTAL SERVICES  
AIRPORT ENGINEERING UNIT  
5300 SOUTH HOWELL AVENUE  
MILWAUKEE, WI 53207  
Telephone 414-747-5774

**DATE OF ADDENDUM:** May 29, 2015

**BIDS CLOSE:** Wednesday, June 3, 2015; 2:00 PM

---

**TO ALL BIDDERS:**

Each bidder shall read this Addendum in its entirety to determine to what extent his proposal and the contract conditions will be affected. This Addendum to the Contract Documents is issued to modify, explain, or correct the original documents and is hereby made part of the Contract Documents.

---

**RECEIPT –** Sign the following receipt and attach to submitted Proposal Form.

---

Receipt of Addendum No. 1, consisting of two (2) pages (this page included), for the LJ – Security & Wildlife Perimeter Fencing 2015 project, Official Notice No. 7019, at Lawrence J Timmerman Airport, Milwaukee, Wisconsin, dated May 29, 2015, is acknowledged.

Date \_\_\_\_\_

Firm \_\_\_\_\_

Per \_\_\_\_\_

Address \_\_\_\_\_

ADDENDUM NO. 1

**LJT – Security & Wildlife Deterrent Perimeter Fencing**  
GMIA Project No. A190-15004

GENERAL MITCHELL INTERNATIONAL AIRPORT  
5300 SOUTH HOWELL AVENUE  
MILWAUKEE WISCONSIN 53207

**OFFICIAL NOTICE NO. 7019**

GENERAL MITCHELL INTERNATIONAL AIRPORT  
Milwaukee County, Wisconsin

**PART 1 – BIDDER'S CLARIFICATIONS**

- 1.1 Bidders are reminded of the following specification notes concerning trenching / backfilling:
  - Specification 34 73 05 Trenching Section 3.2-D : "Do not advance open trench more than 200 feet ahead of installed chain link fencing fabric."
  - Specification 34 73 05 Trenching Section 3.5-D : "Do not leave more than 50 feet of trench open at end of the day."
  - Specification 34 73 05 Trenching Section 3.5-E : "Protect open trench to prevent danger to Owner and the public."
- 1.2 Timing : Per Specification Section 01 04 00, if awarded, bids will be awarded within 120 days of bid, and work shall be completed within 30 calendar days. Work is to be conducted between the hours of 700 and 1700, Monday through Friday. It is the general intention that the work will be done in August / September.
- 1.3 Traffic barricades and silt fencing are not anticipated for this project.

**PART 2 – REVISIONS TO THE PROJECT MANUAL**

2.1 - NONE

**PART 3 – REVISIONS TO THE DRAWINGS**

3.1 – NONE

**PART 4 – REVISIONS TO THE BID SCHEDULE**

4.1 – NONE