

M015-14418  
M016-14419

**ADDENDUM NUMBER:** Addendum - Two  
**PROJECT TITLE:** Milwaukee Public Museum  
**NORTH FAÇADE RESTORATION**  
**Site Number: 275**  
**Building Number: 60**  
**800 West Wells Street**  
**Milwaukee, Wisconsin 53233-1478**

**PROJECT NUMBER:** M015-14418  
M016-14419

**DATE OF ADDENDUM:** November 10, 2014

This Addendum to the Contract Documents is issued to modify, explain or correct the original Documents, Dated OCTOBER 20, 2014 and is hereby made part of the Contract Documents. Acknowledge receipt of this addendum in the space provided on the Bid Form, or bid maybe rejected.

SPECIFICATIONS

SECTION 07 42 43 – COMPOSITE WALL PANELS

Addition to Section 2.1 COMPOSITE PANEL SYSTEM; paragraph A; sub-paragraph 1c, as follows:

- 1c. Sub-Framing: Universe Corporation' 7000 Trespa Attachment System, acceptable manufacturer.  
Exposed fastening on fixed depth aluminum sub-framing tested and meeting the performance requirements of NFPA 285.

END OF ADDENDUM TWO