

BID PACKAGE #2: ADDENDUM NUMBER 1

MILWAUKEE COUNTY CENTRAL FLEET MAINTENANCE BUILDING MODIFICATION: OFFICE ADDITION AND RENOVATION: BID PACKAGE #2
 Site #365, Bldg. #5600
 10320 W. Watertown Plank Rd.
 Wauwatosa, Wisconsin 53226

Project Number: O230-13636

Date of Addendum: February 20, 2014

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated February 12, 2014, and is hereby made part of the Contract Documents.

MODIFICATIONS & CLARIFICATIONS TO SPECIFICATIONS

1. DBE-00 Disadvantaged Business Enterprise (DBE) Utilization Specifications
 - a. Page 1, Paragraph 2, **DELETE** "DBE Goal: This contract's DBE participation goal is 10%" **REPLACE WITH** "DBE Goal: This contract's DBE participation goal is 25%"
2. Specifications Section: 084113 "Aluminum Framed Entrances and Storefronts"
 - a. **REVISE** Hardware Set 02 in specification section 084113-16 with the following:

Set: 02

Doors: 100-1

Description: PH 2 - Exterior - Pair - Alum - Card Reader / Exit Device / Auto Operator

<i>2 Continuous Hinge</i>	<i>MCK-12HD</i>	<i>CL</i>	<i>MK</i>
<i>1 Exit Device (rim, nightlatch)</i>	<i>16 8804 x Less Pull x LC (Provided by owner installed by contractor)</i>	<i>US32D</i>	<i>SA</i>
<i>1 Exit Device (exit only)</i>	<i>16 8810 LC (Provided by owner installed by contractor)</i>	<i>US32D</i>	<i>SA</i>
<i>3 Cylinder (Rim/Mort)</i>	<i>V655_IC x (Provided by owner installed by contractor)</i>	<i>US26D</i>	<i>AA</i>
<i>1 Electric Strike</i>	<i>9400-12/24D (Grade 1)</i>	<i>630</i>	<i>HS</i>
<i>1 ElectroLynx Adaptor</i>	<i>2004M</i>		<i>HS</i>
<i>1 SMART Pac Bridge Rectifier</i>	<i>2005M3</i>		<i>HS</i>
<i>2 Pull</i>	<i>RM202</i>	<i>US32D</i>	<i>RO</i>
<i>1 Surface Closer</i>	<i>2800ST (Push or Pull as applicable)</i>	<i>689</i>	<i>NO</i>
<i>1 Door Operator</i>	<i>6030</i>	<i>689</i>	<i>NO</i>
<i>1 Threshold</i>	<i>279x224AFGT ES14L</i>		<i>PE</i>
<i>2 Sweep</i>	<i>3452AV</i>		<i>PE</i>
<i>1 ElectroLynx Harness</i>	<i>QC-C1500P</i>		<i>MK</i>
<i>1 Request to Exit Sensor</i>	<i>XMS</i>		<i>SU</i>

0039-10452

2 Position Switch	DPS-M-BK	SU
1 Door Switch	503	NO
1 Power Supply	BPS-24-1	SU

Notes: * Weather-strip supplied with aluminum frame & doors.

* Coordinate all wiring & conduit with the electrical contractor.

* Card Reader to be provided as part of Bid Package 3.

* Door contacts monitor the position of the doors and reports status to the security system.

* Mode of Operation: When the correct credential is presented to the card reader the electric strike will release and automatic operator door switch will be activated. The door can be manually opened or the automatic operator door switch can be pressed and the active leaf will open. When the interior automatic operator door switch is pressed the electric strike will release and active leaf will open. Manual egress is allowed at all times.

- b. **REVISE** Specification Section 084113-9, part 2.5, K, 8 dated 2/12/14 with the following:

“ 8. Furnish actuators and other controls

- a. 4 ½” Surface Mounted Weather Proof Wireless Wall Actuator Mount, unless noted otherwise.”

End of Addendum No. 1