

## BIDDER QUESTIONS

Project No.: P191-11437

CALVIN MOODY PARK COMMUNITY  
BUILDING, SPLASH PAD, AND PARK RENOVATION RE-BID

Date: August 13, 2014

Questions and observations:

1. Is there dampproofing on the foundation walls? The architectural drawings show it but the structural do not? (There is no basement level to protect?)

Yes, the dampproofing is required on the foundation walls as indicated on the architectural drawings and specifications. It is there as good practice to minimize the moisture penetration into the foundation walls especially since there are rain gardens around most of the building perimeter.