

BIDDER QUESTIONS

Project No.: P191-11437

CALVIN MOODY PARK COMMUNITY
BUILDING, SPLASH PAD, AND PARK RENOVATION RE-BID

Date: August 14, 2014

Questions and observations:

1. Please provide clarification on the under slab vapor retarder/barrier material. Sheet A500 indicates a vapor retarder and Sheet S301 indicates a 10-mil vapor barrier. Specification Section 03 30 00, 2.03, I to L, has separate materials requirements for vapor retarders and vapor barriers; the 10 mil material is listed under vapor retarder. Additionally, the W.R. Meadows product representative indicated the Premoulded Membrane with Plasmatic Core specified in 2.03, L, 2, b is 110-mil product and the equivalent W.R. Meadows product to the listed Stego 15-mil barrier is the W.R. Meadows Perminator 15-mil barrier.

Contractor to provide a Vapor barrier as defined in specification section 03 30 00, 2.03, L. It minimum thickness shall be 15 mil. The location shall be immediately below the slab on grade. Note that the install of the Infloor radiant heat tubing attachments shall not puncture the vapor barrier at any time. A clarification will be issued by addendum.