

**ADDENDUM NUMBER 01**

PULASKI PARK SWIMMING POOL BUILDING RENOVATIONS  
2701 South 16th Street  
Milwaukee, Wisconsin 53215

NOYES PARK SWIMMING POOL BUILDING RENOVATIONS  
8235 West Good Hope Road  
Milwaukee, Wisconsin 53223

Project Numbers: P399-14620 & P399-14621

Notice Number: 6987

Date of Addendum: 03-23-2015

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated 02-10-2015, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

**SPECIFICATIONS:**

**SECTION 08 63 00 (Metal-Framed Sloped Glazing Systems):**

1. Article 2.1, Paragraph A.3 – Add sub-paragraph “b.”: “Wisconsin Solar Design (Middleton, WI) is an approved manufacturer for this product.”

**DRAWINGS:**

**PULASKI:**

Sheet A1.1

1. Storage Room 101 – Add demolition note #8, which states: “Remove existing steel chain-link fence enclosure system at south end of room. Save and reinstall at same location after new floor is installed.”
2. Storage Room 101 – Delete note bubble #38, shown at south end of room. Not applicable.

Sheet A1.3

1. General Roof Notes, Note Number 2 – Remove two instances of the word “Firestone” and replace each instance with the word “Tremco”.

Sheet M2.1

1. Keyed Plan Notes – Delete Note Number 2.

Sheet M2.3

1. General Notes – Add Note 1 as follows: “Contractor to reference drawing sheet A1.3 for roof construction. Contractor to provide any and all work required for new roof curbs and rails for proper support and installation in strict accordance with Manufacturer’s instructions.”

NOYES:

Sheet A1.1

1. Construction Notes, Note Number 20 – Delete second sentence in it's entirety: "Refer to note 43 regarding painting of exposed spiral duct." (Note 30 accounts for this information.)

Sheet A1.2

1. Construction Notes, Note Number 20 – Delete second sentence in it's entirety: "Refer to note 43 regarding painting of exposed spiral duct." (Note 30 accounts for this information.)

Sheet A1.3

1. Roof Construction Notes, Note Number 3 – Revise to read: "Provide new roof top unit at location of previously removed unit. Refer to Mechanical drawings and schedules."

Sheet A1.3

1. Roof Demolition and Construction Plan 1/A1.3 – Remove note bubble #6 shown at RTU-1. Place note bubble #6 at ACCU-1 and ACCU-2.

Sheet M1.3

1. Keyed Plan Notes, Note Number 4 – Add note as follows and key to existing roof exhauster nearest intersection of column lines H and 1.1: "Remove existing fan and turn over to Owner."

Sheet M2.3

1. General Notes – Add Note 1 as follows: "Contractor to reference drawing sheet A1.3 for roof construction. Contractor to provide any and all work required for new roof curbs and rails for proper support and installation in strict accordance with Manufacturer's instructions."

End of Addendum No. 01