

Project No. P399-14620 / P399-14621

ADDENDUM NUMBER 02

PULASKI PARK SWIMMING POOL BUILDING RENOVATIONS
2701 South 16th Street
Milwaukee, Wisconsin 53215

NOYES PARK SWIMMING POOL BUILDING RENOVATIONS
8235 West Good Hope Road
Milwaukee, Wisconsin 53223

Project Numbers: P399-14620 & P399-14621

Notice Number: 6987

Date of Addendum: 03-24-2015

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated 02-10-2015, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

SPECIFICATIONS:

SECTION 22 30 00 (Plumbing Equipment):

1. Article 2.2 – Delete the words “Close Coupled” from the section heading.
2. Article 2.2, Paragraph B, Sub-Paragraph 1: Delete the words “close coupled” from the sentence.
3. Article 2.2, Paragraph D – Delete the words “Brass, bronze or thermoplastic” and replace with “Brass or bronze”.
4. Article 2.2, Paragraph I – Add paragraph as follows: “Drive: Flexible coupling.”

DRAWINGS:

PULASKI:

Sheet P0.0

1. Plumbing Fixture Schedule – Add tag ET-1: Manufacturer = Amtrol, Model = ST-5C, Remarks = Steel shell, 2.0 gallon tank volume, fixed diaphragm construction, ASME rated, 150 PSIG maximum working pressure.
2. Detail 3 – Duplex Gas Water Heater: Add expansion tank ET-1 to schematic in cold water supply line near connection to recirculation pump discharge line.

End of Addendum No. 02