

Z132-15429

ADDENDUM NUMBER 1

MILWAUKEE COUNTY  
ZOOLOGICAL GARDENS PECK WELCOME CENTER  
WALKWAY DECK REPLACEMENT  
Site #355, Bldg. #4740  
10001 West Blue Mound Road  
Milwaukee, WI 53226

Project Number: Z132-15429

Notice Number: 7142

Date of Addendum: September 12, 2016

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated September 1, 2016, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

DRAWINGS

CHANGE Drawings as follows:

Sheet A2, Fasteners schedule Item #2 - Change "3-1/2"x10-1/2GA DECK NAIL, GALV. STEEL, 6D SPIRAL SHANK FLAT HEAD" to:-

5"X0.20" RING SHANK DTL NAIL, HOT DIP GALV. STEEL.

Sheet A2, Fasteners schedule Item #3 - Change "2-1/2"x10-1/2GA DECK NAIL, GALV. STEEL, 6D SPIRAL SHANK FLAT HEAD" to:-

3"x10-1/2GA DECK NAIL, GALV. STEEL, 6D SPIRAL SHANK FLAT HEAD; OR 3-1/4"X0.14" RING SHANK DTL NAIL, HOT DIP GALV. STEEL.

Sheet A2, Fasteners schedule Item #4 - Change "2"x10-1/2GA DECK NAIL, GALV. STEEL, 6D SPIRAL SHANK FLAT HEAD" to:-

2-1/2"x10-1/2GA DECK NAIL, GALV. STEEL, 6D SPIRAL SHANK FLAT HEAD; or 2-1/2"X0.12" RING SHANK DTL NAIL, HOT DIP GALV. STEEL.

Sheet A2, Fasteners schedule Item #5 - Change "3"x10-1/2GA DECK NAIL, GALV. STEEL, 6D SPIRAL SHANK FLAT HEAD" to:-

4"X0.18" RING SHANK DTL NAIL, HOT DIP GALV. STEEL.

Sheet A2, Fasteners schedule Item #6 - Change "2-1/2"x10-1/2GA DECK NAIL, GALV. STEEL, 6D SPIRAL SHANK FLAT HEAD" to:-

3"x10-1/2GA DECK NAIL, GALV. STEEL, 6D SPIRAL SHANK FLAT HEAD; or 3-1/4"X0.14" RING SHANK DTL NAIL, HOT DIP GALV. STEEL.

Sheet A8 Detail 3/A8 - Change height of spacer from 2" as shown to 1-1/4".

End of Addendum No. 1