

Z132-15429

ADDENDUM NUMBER 2

MILWAUKEE COUNTY
ZOOLOGICAL GARDENS PECK WELCOME CENTER
WALKWAY DECK REPLACEMENT
Site #355, Bldg. #4740
10001 West Blue Mound Road
Milwaukee, WI 53226

Project Number: Z132-15429

Notice Number: 7142

Date of Addendum: September 14, 2016

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated September 1, 2016, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

BIDDING DOCUMENTS AND SPECIFICATIONS

1) CLARIFICATION for Bid form Page 00400-2, Substitution of Materials section:

Bidder desiring to substitute 1-1/4" overlay deck with 2-12" replacement deck may enter a bid on this section as a material substitution by describing the substituting material and the material being substituted. Additionally, bidder shall indicate on this section that details of the substituting bid are on additional pages attached to the bid. The additional pages shall then be attached to the bid form. The substituting bid shall include all work entailed in such a substitute, including addressing all conditions pertinent to the work, known or unknown at time of bidding.

2) CHANGE to Specification SECTION 06 10 10 – DECKING AND CARPENTRY, article 2.3 PRESSURE TREATED LUMBER, paragraph A:

Change the statement "Conform to quality standards stated in applicable references listed in PART 1 above." to:-

"Conform to quality standards per AWPA water based pressure treated pine for use category UC4A."

End of Addendum No. 2