

Z115-13651

ADDENDUM NUMBER 1

MILWAUKEE COUNTY ZOOLOGICAL GARDENS  
GREAT APES BUILDING MECHANICAL ROOM  
ROOF REPLACEMENT  
Site #355, Bldg. #4410  
10001 West Blue Mound Road  
Milwaukee, WI 53226

Project Number: Z115-13651

Notice Number: 6959

Date of Addendum: August 13, 2014

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated August 8, 2014, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

SPECIFICATIONS

Section 07540

Paragraph 3.04-F: Change the entire paragraph to read as follows: -

F. Insulation shall be installed on vapor retarder with adhesive or mechanical fasteners as appropriate for the roof deck material, and as recommended by roof membrane and insulation manufacturers.

Paragraph 3.04-G: Add the following clause to the paragraph title: -  
(Where applicable)

DRAWINGS

Sheet A1 – Note 2-B – DEMOLITIONS: Add the following statement: -


REMOVE EAST-WEST ROOF CURB BETWEEN THE TWO PORTIONS OF MECHANICAL ROOM ROOF, INCLUDING ALL MASONRY MATERIAL.

Sheet A2

Roof Demolition Plan: Remove roof curb as indicated in new note shown in ROOF DEMOLITION PLAN included in SK01 attached to this addendum.


Roof Replacement Plan: Delete roof curb as indicated and shown in ROOF REPLACEMENT PLAN included in SK01 attached to this addendum.

End of Addendum No. 1



### ROOF REPLACEMENT PLAN

1/16" = 1'-0"



### ROOF DEMOLITION PLAN

1/16" = 1'-0"

