

C081-13424

ADDENDUM NUMBER 2

SAFETY BUILDING
COOLING TOWER REPLACEMENT
Site #240, Bldg. #30
821 West State Street
Milwaukee, WI 53233

Project Number: C081-13424

Notice Number: 6890

Date of Addendum: March 6, 2014

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated January 27, 2014, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

DRAWINGS

Sheet ME1 – **CHANGE** voltage on Pumps Schedule for all pumps (P-1, P-2) to 480 Volt / 3 Phase.

Sheet ME3 – **REVISE** Electrical Key Note E3 to read as follows:

"Alternate Bid No. 1 – Provide a AC Duplex Motor Controller with electric alternation circuit to serve Condenser Pumps P-1 and P-2. AC Duplex Motor Controller to be Square D Class 8941, Type DDG30V02 (Allen Bradley, Eaton/Cutler-Hammer, or equal), combination disconnect switch type, NEMA Size 2, 480V, 3 Phase, with NEMA 1 enclosure, to serve (2) 20 HP motors. Connect the duplex motor controller to existing condenser pump motor feeder from the existing motor control center, and connect the outputs from the controller to Pumps P-1 and P-2 (3-#8, #10 ground, in 1" conduit to each pump). Duplex motor controller to be configured to automatically start the "lag" pump only if the "lead" pump fails. Provide a Unistrut support structure to mount the controller adjacent to the two pumps."

End of Addendum No. 2