

ADDENDUM NO. 04

Baggage Screening Improvements – Phase 2B
[Baggage Handling Building Addition and OSR Room]

PROJECT NO. A044-09002-02

OFFICIAL NOTICE NO. 6688

GENERAL MITCHELL INTERNATIONAL AIRPORT
Milwaukee County, Wisconsin

Prepared By: MILWAUKEE COUNTY DEPARTMENT OF
ADMINISTRATIVE SERVICES
Airport Engineers - Telephone 414-747-5320
5300 South Howell Avenue
Milwaukee, Wisconsin 53207

DATE OF ADDENDUM: February 13, 2012

BIDS CLOSE: 2:00 P.M., WEDNESDAY February 15, 2012

TO ALL BIDDERS:

Each bidder shall read this Addendum in its entirety to determine to what extent his proposal and the contract conditions will be affected. This Addendum to the Contract Documents is issued to modify, explain, or correct the original documents and is hereby made part of the Contract Documents.

RECEIPT - Sign the following receipt and attach to submitted Proposal Form.

Receipt of Addendum No. 4, consisting of two (2) pages, for **Baggage Screening Improvements – Phase 2B**, [Baggage Handling Building Addition and OSR Room], Official Notice No. 6688, at General Mitchell International Airport, Milwaukee, Wisconsin, dated January 18, 2012 is acknowledged.

Date _____

Firm _____

Per _____

Address _____

CLARIFICATIONS

Electrical

Q: Does the fiber need to be installed in fiber innerduct when installed in the tray? If so please provide size of innerduct and if it should be plenum rated.

A: Innerduct is required in cable tray. Provide 1-1/2" innerduct. All cabling and innerduct shall be plenum rated. (This is modification from what was issued in Addendum #3)