

ADDENDUM NUMBER: Addendum - One

PROJECT TITLE: Milwaukee County Health & Human Services
Marcia P. Coggs Building
Rebid - Roof Replacement
Site Number: 340
Building Number: 5600
1220 West Vliet Street
Milwaukee, WI. 53205

PROJECT NUMBER: S035-10429

DATE OF ADDENDUM: December 20, 2011

This Addendum to the Contract Documents is issued to modify, explain or correct the construction documents for re-bidding the roof replacement at the Marcia P. Coggs Building, Dated November 09, 2011, and is hereby made part of the Contract Documents. Acknowledge receipt of this addendum in the space provided on the Bid Form, or bid maybe rejected.

SPECIFICATIONS

- Section 07 53 00, Elastomeric Membrane Roofing – Fully Adhered
Revised paragraph 2.2 ELASTOMERIC MEMBRANE (FULLY ADHERED), sub-paragraph A-1
Acceptable manufacturer; adding manufacturer e:
e. Mule-Hide non-reinforced EPDM membrane 60-mil (.060 inches) in thickness, black.
- Section 07 53 00, Elastomeric Membrane Roofing – Fully Adhered
Revised paragraph 2.2 ELASTOMERIC MEMBRANE (FULLY ADHERED), sub-paragraph A-1
Acceptable manufacturer; adding manufacturer f:
f. Versico Roofing System; VersiGard non-reinforced EPDM membrane 60-mil (.060 inches) in thickness, black.
- Section 07 53 05, Elastomeric Membrane Roofing – Mechanically Attached
Revised paragraph 2.1 ELASTOMERIC MEMBRANE – MECHANICALLY ATTACHED, sub-paragraph A. EPDM compounded elastomer, 60-mil thick. Acceptable manufacturer; adding manufacturer 5:
5. Mule-Hide - reinforced EPDM membrane 60-mil (.060 inches) in thickness, black.

END OF SECTION