

Project No. O115-13415, Children's Court Chiller

ADDENDUM NUMBER 1

PROJECT TITLE: Independent Cooling System for Children's Court Project Address: 10201 W. Watertown Plank Road, Wauwatosa, WI. 53226

Project Number: O115-13415

Date of Addendum: 1

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated December 12, 2012 and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in your RFP proposal, or proposal may be rejected.

Please refer to following clarifications and changes to the subject RFP :

1. The proposal due date is being extended to Monday, January 21, 2013 at 2 PM from January 17, 2013.
2. The design will be based on a new power supply for chillers. The consultant will coordinate and assist owner to apply for a new electric power supply rated at 1000 amp, 3 phase, 480 volts.
3. The consultant will be required to perform a cooling load calculations for the entire building and the chillers would be sized using a 10% safety factor.
4. The base design will be based on two air cooled chillers, each sized for 50% capacity. along with an alternate bid design using a single air cooled chiller.
5. Please acknowledge the receipt of this Addendum in your RFP proposal.

End of Addendum No. 1