

ADDENDUM NUMBER 2

MARCUS CENTER FOR THE  
PERFORMING ARTS PHASE IV  
HVAC ASBESTOS ABATEMENT  
Site #270, Bldg. #50  
929 North Water Street  
Milwaukee, WI 53202

Project Number: O038-09416-04

Date of Addendum: February 11, 2013

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated January 21, 2013, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

Project clarifications and bidding questions:

1. What is the abatement material that will be sprayed on the steel prior to our respray?  
*Foster Fiberlock or approved equivalent product shall be applied with an airless sprayer. This is per City of Milwaukee Department of Neighborhood Services requirement.*
2. For the respray, do you want cementitious or noncementitious material?  
*We are not requiring cementitious.*
3. Can we use a fireproof board application like Cafco Board?  
*No. We are requiring the respray.*
4. Does the one-hour rating apply to the member only or does it entail the entire roof deck system?  
*All areas that were originally sprayed shall be resprayed with the approved one-hour rated respray material.*

End of Addendum No. 2