

5046-10474

ADDENDUM NUMBER 4

GENERAL MITCHELL INTERNATIONAL AIRPORT
HANGAR 217 FIRE PROTECTION UPGRADE
6030 South B Street
Milwaukee, WI

Project Number: 5046-10474

Date of Addendum: November 5, 2010

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated September 27, 2010, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

BIDDING DOCUMENTS AND CONTRACT DOCUMENTS

CLARIFICATIONS:

1. There are already standpipes connected to the AAAF system, so there is no need for the 250 gpm hose allowance.
2. The intent of the specification for all piping shall be in accordance with NFPA 13. Schedule 10 piping can be used in all areas as allowed per NFPA 13.

End of Addendum No. 4