

MILWAUKEE TRANSPORT SERVICES, INC.

Wednesday, November 14, 2018

ADDENDUM NO: 1
BID NO: 2018-35 - LOBBY RENOVATIONS
OPENING DATE: NOVEMBER 19, 2018 @ 2:00 PM, CST

TBE GOAL IS 25% - CONTACT THE CBDP OFFICE DIRECTLY WITH ANY QUESTIONS AS LISTED IN BID

ATTACHED IS THE PRE-BID WALK THROUGH MEETING ATTENDANCE SIGN IN SHEET

The following questions were asked:

- Q. Do you have a list of contractors that are Lenel certified along with their contact information?
- A. **MCTS has worked with Convergent Technologies 262-358-8518, VTI 262.649.5280 and Stanley Security 888-995-2324. Any vendor will work as long as they are certified in [Linel equipment](#).**
- Q. For the replacement of the flooring in the elevator, does the elevator maintenance company have to complete that? If so please give the name and contact information of the maintenance company.
- A. **Replacement of the flooring is fine; does not need to be done by Ascend. Installation of badge reader is fine and does not need to be done by Ascend, as long as it does not involve the wiring that makes the elevator car move or function.**
- Q. If work is only to be done during regular business hours, will the work area be closed down during the flooring work or will it be done after hours or on weekends?
- A. **Yes, the flooring work should be done off hours. Please price accordingly.**
-

BID 2018-35

Please sign and return one copy with the BID Documents.

We acknowledge receipt of Addendum #1.

Name

Company Name

Signature

Date